



LOCATION NUMBER	LOCATION	TYPE	SAMPLED FOR
1	ELLIOTT WEST CSO CONTROL FACILITY EFFLUENT CHANNEL (DISCHARGES TO ELLIOTT WEST OUTFALL)	COMPOSITE	TSS, BOD, SETTLEABLE SOLIDS
2	ELLIOTT WEST CSO CONTROL FACILITY PUMP DISCHARGE CHANNEL (DISCHARGES TO WEST POINT)	COMPOSITE	TSS, BOD, SETTLEABLE SOLIDS
3	ELLIOTT WEST CSO CONTROL FACILITY PUMPS	CONTINUOUS	FLOW
4	SAMPLE PIPE JUST UPSTREAM OF DECHLORINATION STRUCTURE	GRAB	PROCESS CONTROL
5	OUTFALL TRANSITION STRUCTURE	CONTINUOUS OPERATION, COMPOSITE, GRAB	pH, CHLORINE RESIDUAL ANALYZER

**FIGURE 10-47  
SAMPLING LOCATION  
SCHEMATIC**



MONTGOMERY WATSON